


639
159



GUJARAT STATE ELECTRICITY CORPORATION LIMITED

Gandhinagar Thermal Power Station, Gandhinagar, India-382041. Ph. 91-79-23215663
Fax: 91-79-23217673, e-mail: gtps@gebmil.com Website: www.gsecl.in
CIN:U40100GJ1993SGCO19988

Ref: GPS/SE(M)/TMD/

No 8 69 21

Date: 15 SEP 2017

To,
Excellent Water Technology
211, Circle "P" Building,
Praladnagar Cross Road, S. G. Highway.
Ahmedabad -380015. (Guj.) India

E-mail: info@excellentwater.in

Sub: Performance of Kashyap - anti scale system installed in various Cooling water pipes in unit#3 ,4 & 5 at GTPS.

Ref: Your Mail Dt. 5.9.17

With ref. to above, it is to state that you have installed Kashyap-anti scale system, Model pipe dia 8" (#3 BFP cooler inlet), 20" size (#4 ACW line to TG lube oil cooler) and 1600 mm (#5 Condenser outlet line) for demonstration free of cost.

It is to state that, before installation of antiscala system in 8"line, the BFP lube oil cooler tubes were choked and was difficult to clean the tube mechanically, i.e. by inserting hard lance. After installation of anti scale system, it is observed that, the hard scale found loose and the cooler cleaned by water jetting and mechanical cleaning.

The letter is issued upon specific request by you vide mail Dt. 5.9.17

(S.S.Gamit)
Chief Engineer (Gen)
GSECL TPS, Gandhinagar.

47 14-

28/9/17